



Xenon International Acceptance Test Phase 1

James Hayes¹, Matthew Cooper¹, James Ely¹, Warren Harper¹,
Michael Mayer¹, Mark Panisko¹, Michael Howard², Kevin Carter²,
Tricia Gomulinski², Robert Mikulyak², Aaron Orr²; Ryan Sayne²

¹ Pacific Northwest National Laboratory ² Teledyne Brown Engineering

P3.1–616



Funding for this research effort was provided by
the Defense Threat Reduction Agency, USA.
Cleared for Release



PNNL-SA-163172

Xenon International Acceptance Test Phase 1

James Hayes¹, Matthew Cooper¹, James Ely¹, Warren Harper¹, Michael Mayer¹, Mark Panisko¹, Michael Howard², Kevin Carter², Tricia Gomulinski², Robert Mikulyak², Aaron Orr², Ryan Sayne²

¹ Pacific Northwest National Laboratory, ² Teledyne Brown Engineering



Xenon International is a next generation radioxenon monitoring system that was developed at PNNL and being manufactured at Teledyne Brown Engineering (TBE) to strengthen nuclear test monitoring and has recently completed phase-1 testing for acceptance as a qualified system for the International Monitoring System (IMS). Xenon International processes samples every 6 hours generating over 2.5 cc of xenon gas that is counted in a beta-gamma coincidence detector for 12 hours resulting in unprecedented detection limits for radioxenon isotopes. Phase 1 testing was conducted at TBE and consisted of a PTS acceptance visit, radioxenon spikes processed on Xenon International, and 6 months of uninterrupted automated sampling and analysis. Radioxenon analysis data was automatically sent to the PTS after the finish of each count. Xenon International completed phase 1 testing with >98% uptime, and routinely detected never-before seen radioxenon isotopes in an IMS station including ^{125}Xe , ^{127}Xe , and $^{129\text{m}}\text{Xe}$. This talk will discuss Xenon International performance during phase-1 testing and will discuss the impact of unexpected radioxenon isotopes on detection of treaty verification radioxenon radionuclides.

Xenon International Acceptance Test Phase 1

First 6 months

INTRODUCTION


- The Xenon International (XIX81) has completed the first 6 – months of the PTS acceptance test at Teledyne Brown Engineering (TBE), located in Knoxville Tennessee.
- The Phase-1 test period included samples, identified by collection stop date/time in UTC, from April 18, 2020, 00:59:34 through October 18, 2020, 04:52:39.
- The acceptance test began prior to the PTS acceptance test visit where PNNL supplied the PTS with familiarization documents describing the Xenon International operations, measurements, calculations, and calibration methods.
- The team at TBE and PNNL attended the acceptance test visit where the PTS reviewed the Xenon International operations against the acceptance test visit requirements.
- During the visit, the PTS injected a spike sample and performed several tests on the system.
- For the following 6 months, the Xenon International operated unattended and reported data directly to the PTS.
- After the 6-month operations, another spike test was performed and evaluated by GBL15 in the UK.
- This poster highlights the first 6 months of operation and the results of the spike test and an unusual signature observation during the test.

Disclaimer: The views expressed on this poster are those of the author and do not necessarily reflect the view of the CTBTO PrepCom

Xenon International Acceptance Test Phase 1


Xenon International Technical Goals and Specifications

- **High sensitivity**
 - 6-hour collection, 4 samples per day, continuous sampling 24/7, 100% duty cycle
- **High flow rate** 100 L/min (stp; 0°C, 760 torr)
 - MDCs: ^{133}Xe : 0.15 mBq/m³, ^{135}Xe : 0.5 mBq/m³, $^{131\text{m}}\text{Xe}$: 0.15 mBq/m³, $^{133\text{m}}\text{Xe}$: 0.15 mBq/m³
- **High reliability and uptime**
 - PNNL software and hardware control
 - Included manufacturer in design phase
 - 2-years of testing during development
 - Demonstrated combined uptime 97.8%
- **Reduce/eliminate consumables**
 - Nitrogen carrier gas (nitrogen generator on-site)
- **Small weight and size of the system over currently deployed systems**
 - 1240 kg, 80 cm X 109 cm X 194 cm
- **Low power and heat load** compared to current IMS xenon systems
 - 208 VAC (160-275 volt), 50/60 Hz, 30 amp circuit, 4kW (3.5 kW for Xenon International without nitrogen generator)







Xenon International Acceptance Test Phase 1 Expected Signatures

- Xenon International uses 7 Region of Interest analysis method
- Monitored radioxenon isotopes: ^{133}Xe , $^{133\text{m}}\text{Xe}$, $^{131\text{m}}\text{Xe}$, ^{135}Xe



The seven ROI analysis approach provided as a two-dimensional (2D) electron- photon (beta-gamma) plot [2].


Disclaimer: The views expressed on this poster are those of the author and do not necessarily reflect the view of the CTBTO PrepCom




Xenon International Acceptance Test Phase 1

Unexpected Signatures


- During the 6-month test, the Xenon International unusual signatures observed which interfered with analysis by overlapping with regions of interest
- See: **James Ely - O2.4-138, First observations of environmental ^{125}Xe , ^{127}Xe , and $^{129\text{m}}\text{Xe}$.**



^{125}Xe observed with ^{135}Xe




^{125}Xe observed with ^{135}Xe , ^{133}Xe , and $^{131\text{m}}\text{Xe}$




^{127}Xe observed with ^{135}Xe

- XIX81 Xenon International archive bottles sent to UK for analysis of acceptance test performance samples




Comparison of ^{133}Xe results from XIX81 and GBL15




Comparison of $^{131\text{m}}\text{Xe}$ results from XIX81 and GBL15

- XIX81 Xenon International analysis results compared to Autostrada developed by the IDC




Comparison of ^{133}Xe results from XIX81 and Autostrada




Comparison of ^{135}Xe results from XIX81 and Autostrada

- XIX81 Xenon International analysis results compared to Autostrada developed by the IDC



Comparison of ^{131}mXe results from XIX81 and Autostrada



Comparison of ^{133}mXe results from XIX81 and Autostrada

Xenon International Acceptance Test Phase 1

System Data Availability Performance

RESULTS

- The data availability (uptime) is calculated by dividing the samples received that met the quality objectives divided by the possible samples of the test duration.
- First collection start 4/17/2020 18:59 (GMT)
- Last collection stop 10/18/2020 16:52 (GMT)
- 735 possible samples
- 12 samples were missing or did not meet quality criteria (unofficial results)
- Uptime 98.4%**

Category		Value	Units
Xenon volume	>	0.2	cc
133 MDC	<	5	mBq/scm
Collection time	>=	3	hrs
	<=	12	hrs
Acquisition time	>=	6	hrs
	<=	24	hrs
Reporting time	<=	72	hrs

Xenon International Acceptance Test Phase 1 *Upgrades and Documentation for Phase 2*

- Additional documentation was completed for preparation for Phase 2:
 - Xenon International User Manual
 - Description of the quantification procedure
 - Limited user-maintenance manual
 - Report on stable xenon collection efficiency
 - State of Health (SoH) parameters
 - Acceptance Test Report
- Software was also updated in preparation for Phase 2:
 - Data reporting format including the collection efficiency in phd files
 - Partial SoH file during system shutdown
 - On/off alert during power outage
 - Data authentication
 - SoH 10-minute average
 - Labeling spike data
- New coated beta cells were assembled, installed and calibrated.

- June 2021, TBE will train the operators from German Federal Office for Radiation Protection (BfS) via teleconference.
- Xenon International will be shipped to Germany June 11th, 2021.
- Xenon International is expected to be delivered before June 28th when TBE is scheduled to begin installation.
- On-site training is scheduled for the first week of July.
- Phase 2 testing is expected to start during the middle of July.

